



**Bids and Awards Committee**

**Bid Bulletin No. 1**

**Supply of Services for the Hosting/Co-Location Facility of SEC**

All prospective bidders are hereby informed of the following:

**AMENDMENTS:**

Item No.	From	To
Deadline for the submission and receipt of Bids	March 28, 2017 on or before 9:00 am at the Function Room A, 2 <sup>nd</sup> Floor, Secretariat Building, PICC Complex, Pasay City	March 27, 2017 on or before 9:00 am at the Procurement Division, 3 <sup>rd</sup> Floor, Secretariat Building, PICC Complex Pasay City
Opening of Bids	March 28, 2017, 9:00 a.m. at the Function Room A, 2 <sup>nd</sup> Floor, Secretariat Building, PICC Complex, Pasay City	March 27, 2017, 9:00 a.m. at the Function Room B, 2 <sup>nd</sup> Floor, Secretariat Building, PICC Complex, Pasay City
<b>P. 64 Section VII. Technical Specification</b>	<b>Installation lead time 30 days upon receipt of work order/Notice to Proceed</b>	<b>Installation lead time 45 days upon receipt of work order/Notice to Proceed</b>
<b>Additional References</b>  Annex A – List of Equipment for Co-Loc Annex B - Network Layout Annex C - List of Authorized Provider of SEC		

**CLARIFICATIONS:**


ITEMS	CLARIFICATIONS
<b>P. 64 Section VII. Technical Specification Other Requirements</b>  <b>Technical Training for two (2) SEC IT personnel on Network Administration/Management/Configuration and Security coursed from accredited training providers</b>	<b>Local Training</b>
<b>P. 61 Section VII. Technical Specification Cage/Co-Location Area</b>	

At least 30 sqm. of space (6m x 5m)	Area: 30 sqm Cage: 5m x 6m
Must provide at least two (2) unit of 42U data cabinet (No. of existing racks-4)	Must provide at least two (2) unit of 42U data cabinet, four(4) current existing racks – Three(3) owned by SEC and One(1) provided by current service provider.
P. 62 Section VII. Technical Specification Other facilities  In-House Media safe storage for SEC file backups	Digital Fire Safe Exterior (HxWxD) - 121.0 cm x 64.6 cm x 60.8 cm Key and Digital lock combination Steel construction 2 multi-position shelves
Specify average number of tapes consumed on quarterly basis	Average of 12 pcs. LTO5 Tapes Media
P. 64 Section VII. Technical Specification Contract duration  Installation lead time 30 days upon receipt of work order/Notice to Proceed	Installation lead time 45 days upon receipt of work order/Notice to Proceed


This Bid Bulletin No. 1 shall form an integral part of the Bid Document.

March 20, 2017

Prepared by:

  
Christian Noel D. Castillo  
BAC Secretariat

Reviewed by:

  
Rodel S. Preseo  
End-User Representative

Approved by:

  
Emmanuel X. Artiza  
BAC Chairman

Annex A – List of Equipment for Co-Loc

Item No.	Brand & Model	Year Purchased	Equipment Description	Qty	Space Requirement		Power Rating			Heat Dissipation (BTU/hr)
					(LxWxH mm)	RU	AC/DC	Watts	Volts	
1	SunFire V880	2002	Entry-level Server, 4 CPU	2		17	220	2880		9829
2	SunFire V240	2005	Entry-level Server, 4 CPU	2		2	220	400		805
3	SunFire E4900	2005	Midrange Server, 8 CPU	1		17.5	220	4180		14260
4	Oracle Enterprise M4000	2010		1		6	220	2350	2 x 100 – 240V AC	8018
5	Oracle SPARC T4-4	2013		1		5	220	2770		9362
6	Oracle SPARC T5-2	2013		1		5	220	2770		9362
7	C4 Tape Library	2005		1	6.75" x 19" x 31"		220	900		3070
8	Hitachi Unified Storage 130	2012	Fiber Channel Disk Storage System	1		EIA 19" rack mounted, 10U	220	2000		7320
9	HP Desktop PC			1	19" x 28" (LxW)		220	120		160.37
10	FortiGate-110c	2010		1	10" x 28" (LxW)		220	120		160.37
11	Brocade 200e SAN Switches	2008	FC SAN Switches	2		2	220	120 (60W each)		308 (154 each)

12	3COM Baseline Switch 2226-SGT Plus			1		17.5"x6.5"				100- 240V AC	
13	Cisco Catalyst Switch			2		17.5	220	86			294
14	Hitachi CR220S	2014	Entry Level Server	2		2	220	800			308
15	Ianberg External Drive LT05	2014	Tape Drive	1			220	30			
16	FortiGate-300c	2015		1	44 x 432 x 322		220	154			525
17	Oracle SPARC T5-2	2016		1		5	220	2770			9362
18	Oracle SPARC T5-2	2016		1		5	220	2770			9362
19	Oracle SPARC T5-2	2016		1		5	220	2770			9362
20	Oracle Server XS-2	2016		1		5	220	2244			9362

Annex B Network Diagram

