



Bids and Awards Committee

Bid Bulletin No. 1

Hosting and Co-Location Facility of SEC

All prospective bidders are hereby informed of the following:

Clarification	SEC Response
<p>List of Equipment for Co-loc, Page 62-63:</p> <ul style="list-style-type: none"> o Kindly please provide the final list of hardware to be collocated since as per pre-bid there will be additional HW to be included. 	<p>See attached updated Annex A – List of Equipment for Co-Loc</p>
<p>In regards with the item security and surveillance system, page 57:</p> <ul style="list-style-type: none"> • kindly please confirm if the required 24x7 physical access security, biometrics and proximity access/controls are to be installed in the cage or is it pertains to the datacenter building as a must have feature? • If inside the cage, kindly please confirm if the Biometrics and proximity access is required for both in and out. 	<ul style="list-style-type: none"> • It pertains to the datacenter where the cage is located. • Not applicable
<p>Kindly please provide the required camera specifications and its preferred camera position each.</p>	<ul style="list-style-type: none"> • Closed Circuit digital TV Security Monitoring that can be remotely accessed by SEC for monitoring purposes with the following requirements: <ul style="list-style-type: none"> a. Remotely access thru internet b. Separate DSL connection c. At least three(3) units of Camera strategically located to cover all area with proper lighting at all times d. At least 30 days of recording on internal drive and six(6) months recording on archive or external drive.

Handwritten mark

<p>Kindly please confirm if we can provide Colocation area only since fixed cage is an option as stated “There should be a Fixed Cage or co-location area”.</p>	<ul style="list-style-type: none"> • There should be a Fixed Cage since the requirement is a Wire mesh cage.
<p>If fixed is required, may we request to minimize the required space since the equipment’s below would fit 6 units of 42RU rack with allowance for expansion already.</p>	<ul style="list-style-type: none"> • The required space remains at 30 sqm. of space.
<p>Domain Name/Parking, Page 58:</p> <ul style="list-style-type: none"> ◦ Kindly please confirm how many domain names to be parked? ◦ Kindly please advise preferred domain name and Extension(.com, .net, .org, .com.ph, .ph, etc..). 	<ul style="list-style-type: none"> • Currently SEC has 12 domain name under sec.gov.ph. • gov.ph
<p>Re webhosting, kindly please provide required specifications: § CPU, RAM, HDD, OS(windows or linux), DB license(SQL?).</p>	<ul style="list-style-type: none"> • The requirement is 16 GB size of space for the static web page.
<ul style="list-style-type: none"> • Other Facilities, page 58: <ul style="list-style-type: none"> ◦ In the span of the contract term, kindly advise maximum number of required use of overnight rooms. ◦ Kindly advise number of SEC authorized personnel to do overnight shifts. 	<ul style="list-style-type: none"> • No specific number of user, only if needed. • Maximum of 6 authorized personnel
<ul style="list-style-type: none"> • Required Services, page 58 <ul style="list-style-type: none"> ◦ Requesting to remove the Item “Required Services” to a have an equal footing with the current coloc provider since they don’t have to include this as part of the total cost. 	<ul style="list-style-type: none"> • The “required services” cannot be removed considering it is necessary and/or essential to the project.
<p>Technical Documents for Submission, page 60:</p> <ul style="list-style-type: none"> ◦ in regards with the 100Kms radius from the proposed co-location facilities to the offsite media safe storage location of SEC may we request to minimize or lowered down to 70Kms. 	<ul style="list-style-type: none"> • 100Kms radius is retained
<p>Connectivity:</p> <ul style="list-style-type: none"> ◦ Kindly please clarify if the primary and secondary ISP/DLL should be provided by different telcos (labeled as “third party” on the network diagram). Would last-mile diversity suffice? 	<ul style="list-style-type: none"> • This pertains to “CIR 10Mbps third party secondary leased circuit via a fiber optic cable from the IDC to SEC’s DC” as indicated in page 58.

A

AMENDMENTS:

Item No.	From	To
P, 36 Section III. Bid Data Sheet Item no. 21	The deadline for submission of bids is on December 5, 2018, 9:30 am	The deadline for submission of bids is on December 5, 2018, <u>1:30 pm</u>
P, 36 Section III. Bid Data Sheet Item no. 22	The opening of bids is on December 5, 2018, 9:30 am	The opening of bids is on December 5, 2018, <u>1:30 pm</u>
P.57 Section VII. Technical Specifications Civil Architectural Mechanical Security and Surveillance System	Reasonably free from dust/dirt Facilities from hauling/Transporting ICT equipment within the area Closed Circuit digital TV Security Monitoring, can be remotely accessed by SEC for monitoring purposes. Remotely access CCTV Recordings	Reasonably free from dust and dirt Facilities from hauling and Transporting ICT equipment within the area Closed Circuit digital TV Security Monitoring that can be remotely accessed by SEC for monitoring purposes with the following requirements: <ul style="list-style-type: none"> a. Remotely access thru internet b. Separate DSL connection c. At least three(3) units of Camera strategically located to cover all area with proper lighting at all times At least 30 days of recording on internal drive and six(6) months recording on archive or external drive.
P.58 Section VII. Technical Specifications Telecommunication Facilities Required Services	Provision for fifteen (15) usable public IP addresses Must provide Domain name hosting/parking Connecting: Power/Network Assistance in the Deployment of	Provision for thirty (30) usable public IP addresses Must provide Domain name hosting or parking Connecting: Power and Network Assistance in the Deployment of Application, DB, OS and others

	Application/DB/OS/etc.	
P.59 Section VII. Technical Specifications		
Service Level Agreement	At Least 99.5% uptime on all facilities and internet connection included in the contract and network at any point in time/daily	At Least 99.5% uptime on all facilities and internet connection included in the contract and network at any point in time or daily
Contract Duration	Installation lead time 45 days upon receipt of work order/Notice to Proceed (NTP)	Installation lead time 45 days upon receipt of work order or Notice to Proceed (NTP)
P.60 Section VII. Technical Specifications		
Technical Documents for Submission	Duly notarized statement stating that cost of dismantling/ disconnecting/ transportation/ migration/deployment and all other incidental costs for the deployment shall be borne by the winning bidder. Duly notarized statement of ownership of the building where the IDC facilities are located or duly notarized certification that the duration of the leasing agreement is at least five (5) years from awarding of contract (copy of leasing agreement should be attached to the certification)	Duly notarized statement stating that cost of dismantling, disconnecting, transportation, insurance, migration, deployment and all other incidental costs for the deployment shall be borne by the winning bidder. Duly notarized statement of ownership of the building where the IDC facilities are located or duly notarized certification that the duration of the leasing agreement is at least five (5) years from awarding of contract (copy of leasing agreement should be attached to the certification)
Annexes	Annex A – List of Equipment for Co-Loc	See attached updated Annex A – List of Equipment for Co-Loc
Page 77, Statement of all Ongoing Contracts Including Awarded but not yet Started Government and Private Contracts, whether similar or not similar in Nature and Complexity to the	Submitted by: Company Name: _____ Authorized Representative: _____ Designation: _____ Date: _____	Submitted by: Company Name: _____ Authorized Representative: _____ (Signature over printed name) Designation: _____ Date: _____ See revised form Annex "B"


Contract to be Bid		
Page 78, Statement of Single Largest Completed Contract Similar to the Contract to be Bid within the Five (5) Years Period	Submitted by: Company Name: _____ Authorized Representative: _____ Designation: _____ Date: _____	Submitted by: Company Name: _____ Authorized Representative: _____ (Signature over printed name) Designation: _____ Date: _____ See revised form Annex "C"


ADDITIONAL INSTRUCTION


The Approved Budget for the Contract (ABC), shall be funded through the authorized appropriations under the FY 2019 National Expenditure Program. Notice of Award shall be issued once the 2019 General Appropriations Act is approved by Congress.


This Bid Bulletin No. 1 shall form an integral part of the Bid Document.

November 27, 2018

Prepared by:

Christian Noel D. Castillo
BAC Secretariat
Representative

Reviewed by:

Grace T. Amberong
End-User

Noted by:

Roseller N. Capria
Head, BAC Secretariat

Approved by:

Armando A. Pan, Jr.
BAC, Vice-Chairman

Annex A – List of Equipment for Co-Loc

Item No.	Brand & Model	Year Purchased	Equipment Description	Space Requirement		Power Rating			Heat Dissipation (BTU/hr)
				Qty	(LxWxH mm)	RU	AC/DC	Watts	
1	SunFire V880	2002	Entry-level Server; 4 CPU	2		17	220	2880	9829
2	SunFire V240	2005	Entry-level Server; 4 CPU	2		2	220	400	805
3	SunFire E4900	2005	Midrange Server; 8 CPU	1		17.5	220	4180	14260
4	Oracle Enterprise M4000	2010		1		6	220	2350	8018
5	Oracle SPARC T4-4	2013		1		5	220	2770	9362
6	Oracle SPARC T5-2	2015		1		5	220	2770	9362
7	C4 Tape Library	2005		1	6.75" x 19"31"		220	900	3070
8	Hitachi Unified Storage 130	2012	Fiber Channel Disk Storage System	1		EIA 19" rack mounted-10U	220	2000	7320
9	HP Desktop PC	2009		1	19"x28" (LxW)		220	120	160.37
10	FortiGate-110c	2010		1	10"x28" (LxW)		220	120	160.37

11	Brocade 200e SAN Switches	2008	FC SAN Switches	2		2	220	120 (60W each)		308 (154 each)
12	3COM Baseline Switch 2226-SGT Plus	2010		1		17.5"x6.5"	220		100-240V AC	294
13	Cisco Catalyst Switch	2002		2		17.5	220	86		294
14	Hitachi CR2205	2014	Entry-level Server	2		2	220	800		308
15	Tanberg External Drive LTO5	2014	Tape Drive	1			220	30		
16	FortiGate-501e	2018		1			220	154		525
17	Oracle SPARC T5-2	2016		1		5	220	2770		9362
18	Oracle SPARC T5-2	2016		1		5	220	2770		9362
19	Oracle SPARC T5-2	2016		1		5	220	2770		9362
20	Oracle Server T5-2	2016		1		5	220	2244		9362
21	Oracle Server T5-2	2017		1		5	220	2244		9362
22	Acer Desktop Server	2016		1	19"x28" (LxW)		220	120		160.37
22	Acer Desktop Server	2017		3	19"x28" (LxW)		220	120		160.37
23	Supermicro CSE-846E1-R900B	2018		1		4	220	900		
24	Brocade VDX 6710	2018		1		2	220	200		
25	HP Procurve 2530-48	2016		1		2	220	200		

Statement of all Ongoing Contracts including Awarded but not yet Started Government & Private Contracts, whether similar or not similar in nature and complexity to the contract to be bid

Name of Contract (Project Title Name of Entity)	Date of contract	Contract duration	Owner's name and address	kind of Goods	Amount of contract	Value of outstanding works	Date of Delivery <i>(Date of Delivery shall refer to the expected date the project shall be fully completed or delivered)</i>

Note:

- 1. Renewed/extended contracts shall be considered as on-going contracts.*
- 2. Project's under non-disclosure agreement (NDA) should be included per GPPB NPM-034-2014*

Instructions:

- a) If there is no ongoing contract including awarded but not yet started as of the aforementioned period, state none or equivalent term.
- b) The total amount of the ongoing and awarded but not yet started contract should be consistent with those used in the Net Financing Contracting Capacity (NFCC) in case an NFCC is submitted as an eligibility documents

Submitted by:

Company Name: _____

Authorized Representative: _____

(signature over printed name)

Designation: _____

Date: _____

Statement of Single Largest Completed Contract similar to the contract to be bid within the five (5) years period

This is to certify that the project named below is the Single Largest Completed Contract similar to the contract to be bid, within the five (5) years period

Name of Contract (Project Title and Name of Entity)	Date of contract	Contract duration	Owner's name and address	Kind of Goods	Amount of completed contracts, adjusted by the bidder to current prices using PSA's consumer price index, if necessary	Date of Delivery <i>(Date of Delivery shall refer to the date the project was fully delivered or completed)</i>

Note: Bidder shall attach the following:

1. Photocopy of approved Contract or Purchase Order/Work Order
2. End-user's Certificate of Completion or Acceptance from bidder's client or Official Receipt issued for the contract covering the full amount of the contract

Submitted by: _____
 Company Name: _____

Authorized Representative: _____
 (signature over printed name)
 Designation: _____
 Date: _____